

Quality on Tap Report 2021

Town of West Yellowstone – PWSID MT#0003136

P.O. Box 1570 – West Yellowstone, MT 59758

Jon Brown – Operator – 208-240-0534

jbrown@townofwestyellowstone.com

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Our water source is groundwater from Whiskey Springs. It is one of the most pristine groundwater sources in the country. The spring is located five miles southwest of West Yellowstone. Whiskey Springs is without question "Quality on Tap".

Source water assessment and its availability

We have a source water protection plan that is available from our office providing more information, such as potential sources of contamination. This plan was completed in order to protect our pristine water supply from future contamination. It is available for viewing and input during normal office hours. We are pleased to report our drinking water meets federal and state requirements. This report is available for review online at <https://deg.mt.gov/water/Programs/dw-sourcewater>.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Our water source does contain fluoride and is monitored quarterly or more often, as required by our monitoring schedule. Our water contains 2.3 – 3.9 mg/L and the maximum contaminant level set by the EPA is 4 mg/L.

How can I get involved?

This report shows our water quality and what it means. If you have any questions about this report or concerning your water utility, please contact Town Offices at (406) 646-7795. We want our valued customers to be informed about their water utility.

If you want to learn more, please attend any of our regularly scheduled town council meetings. They are held on the first and third Tuesday each month at the Town Hall at 7 p.m.

Total Coliform (TCR)

Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.

Additional Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Town of West Yellowstone is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Additional Information for Arsenic

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Water Quality Data Table

The table below lists all of the drinking water contaminants that we detected during the period of January 1st to December 31st, 2021. The presence of contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Inorganic Contaminants								
Arsenic (ppb)	0	10	2	0	2	2021	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	.00111	.00101	.00101	2018	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4	4	3.8	2.5	3.77	2021	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Mercury (ppm)	2	2	.0176	.0176	.0176	2018	No	Erosion of natural deposits; discharge from refineries, factories
Nitrate [measured as Nitrogen] (ppm)	10	10	0.142	0.135	0.142	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Microbiological Contaminants								
Total Coliform (TCR) (positive samples/month)	0	1	1	NA	NA	2021	No	Naturally present in the environment
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	1.8	NA	NA	2017	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	2.8	NA	NA	2017	No	Erosion of natural deposits
Uranium	0	30	0.8	0.3	0.8	2021	No	Erosion of natural deposits

Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source
Inorganic Contaminants							
Copper - action level at consumer taps (ppm)	1.3	1.3	.312	2021	0	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead – action level at consumer taps (ppb)	0	15	1.00	2021	0	No	Corrosion of household plumbing systems; erosion of natural deposits

Violations and Exceedances

Arsenic - Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with the circulatory system, and may have an increased risk of getting cancer.

The violation is considered a major routine monitoring violation. It began 04/01/2021 and ended 06/30/2021. We submitted our water samples on time and tests were completed on time, however due to issues at the lab results were not supplied to the Town of West Yellowstone in time to remain compliant with regulations. The sample results; once received; did confirm our Arsenic levels were safe and well below EPA standards during this sampling period of 04/1/2021 to 06/30/2021, but because of the labs failure to return our results in a timely manner, we are forced into non-compliance for the monitoring period indicated. We have continued routine monitoring after 06/30/2021 and our results have also been well below EPA standards.

Fluoride - Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease and tenderness of the bones. Fluoride in drinking water at half of the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis may include brown staining and/or pitting of teeth, and occurs only in developing teeth.

The violation is considered a major routine monitoring violation. It began 07/01/2021 and ended 9/30/2021. We failed to test our drinking water for the contaminant and period indicated. Because of this failure we cannot be sure of the quality of our drinking water during the period indicated. We resumed routine monitoring after 9/30/2021 and our results are well below EPA standards.

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
positive samples/month	positive samples/month: Number of samples taken monthly that were found to be positive
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

For more information please contact:

Town Offices - 440 Yellowstone Ave - West Yellowstone, MT 59758 - (406) 646-7795
Jon Brown – Operator – 208-240-0534, jbrown@townofwestyellowstone.com